

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NW-9301BU0298Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Hans Sasserath GmbH & Co. KG Mühlenstraße 62, D-41352 Korschenbroich
Distributor <i>Vertreiber</i>	Hans Sasserath GmbH & Co. KG Mühlenstraße 62, D-41352 Korschenbroich
Product Category <i>Produktart</i>	filters, filter combinations, domestic water units: filter for domestic installation (9301)
Product Description <i>Produktbezeichnung</i>	cartridge filter respectively reversible flow filter for the drinking water installation
Model <i>Modell</i>	TWS FR; TWS FF
Test Reports <i>Prüfberichte</i>	laboratory control test: KT 097/12 from 09.07.2013 (TZW) mechanical test: FO 087/08 - FO 089/08 from 17.07.2009 (TZW) mechanical test: FO 090/08 - FO 092/08 from 14.07.2009 (TZW) KTW testing: K-232369-13/Ko/st from 22.07.2013 (WHY) hygienic testing: W-233281-13-SI from 31.07.2013 (WHY)
Test Basis <i>Prüfgrundlagen</i>	DIN EN 13443-1 (01.12.2007) DIN 19628 (01.07.2007) UBA METALLE (02.04.2015) BGA KTW (12.12.1985) UBA KTW (07.10.2008) DVGW W 270 (01.11.2007)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	17.07.2019 / 15-0222-WNR

06.05.2015 GI A-1/2

Date, issued by Sheet Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 for certification of products for energy and water supply industry.

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
TWS FR; TWS FF	pressure rating: PN 16 nominal diameter: DN 20	
TWS FR; TWS FF	pressure rating: PN 16 nominal diameter: DN 25	
TWS FR; TWS FF	pressure rating: PN 16 nominal diameter: DN 32	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
TWS FR	reversible flow filter
TWS FF	cartridge filter